


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 1013 / 11.03.2010**

NUMBER	1013	DATE	11 / 03 / 2010
---------------	-------------	-------------	-----------------------

Client's data:	ALUMINCO S.A. ALUMINIUM SYSTEMS THESEI MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE
Product description:	SINGLE SASH DOOR OPENING
Material:	ALUMINIUM
System:	AL 590



Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 2B
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C4

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPAPOPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL